



BOQ for the rehabilitation of one water yard and equipped with a solar power system in Al-ghisenab West site

Date of BoQ		23-Nov-25			
HA - Sudan Al Jazeera State office					
#	Items	Unit	Quantity	Unit Cost (SDG)	Total Cost SDG
	Supply and install Solar power system				
2	Provide and installation of Inverter Motor 11 KW, 380 V.Rated Output Power 11kw,(parallel system), Absolute DC input voltage between (380~415 v),	PCS	1		
3	Supply and installation of Solar Panel equivalent to Jinko 550 Watt ,Power output (W)590 W Cell Type: mono-or poly crystalline, Operating PV temperature ranges between -10 °C & + 85 °C., Module Efficiency shall be at least 19%. The PV module frame should be made from Anodized Aluminum. The Photovoltaic modules should be manufactured not before 2025. The warranty for module defects after installation should be at least 20 years. The awarded Proposer shall provide a manufacturer's power guarantee for all PV modules that will be installed with their serial numbers, which guarantees that the loss of the output is not more than 10% during the first 10 years and up to 20% in total after 25 years.	PCS	20		
5	Supply and install MC4 Male and Female junctions	PCS	4		
6	Supply and install Electric Cable DC 10 mm.	ML	70		
7	Supply and installation of Protection box with suction DC fan with Fuse 1000 V, 100 Amp, size 40 CM X 60 CM	box	1		
8	Supply and installation of Change Over Switch 100 Amp,equvelent to Germany or India mark.	box	1		
9	Supply and installation of control panel with Contactor ,overload 20 Amp , Circuit Breaker three phase AC 63 Amp	box	1		
10	Supply and installation of Stand for Solar Panel ,Manufacture and assembly of steel solar panel holder for 20 panel , It must be painted against rust and agreed paint (blue)	stand	1		
11	Supply and installation of DC Junction Box with Circuit Breaker 100 Amp	box	1		
12	Provide and installation of sing Board 1 with Human Appeal and UNICEF and Uk Logo 1 M X 1.5 M and legs 1 m.	Signboard	1		
	Main water pipe line				
13	Supply and installation HDPE pipe 3 inch, including digging installation and backfilling the work will ensure all engineering specifications and standard.	ML	220		

	Fence with dimension 15 m *15 m				
15	Provide materials (Gabain sheet 2mm thickness, Height 1.8 m, length 75 m, heavy Angular iron 3 mm thickness, 3 inch size columns, cement, gravel, sand, Iron bar 12mm, tie wire, painting, and carry out the installation of fencing for area 15 m long *15 m wide, with 15 m partition, cut the heavy 2.2 m and fixed with concrete ratio 1:2:4 footing size (0.40m x 0.40m x 0.50m). and weld the corners supported heavy angle 1.2 m and fixed with interval of 2.5 m and apply the Gabain with full tightened with steel wire (2mm) at each 0.50m and diagonally between supports. supply iron bar 12 mm and welded horizontally three strips with interval of 0.7 m, ensure all engineering specification and SWC standard.	ML	135		
16	Supply a metallic angle heavy and cut it 0.5 m and weld it at the top of the distributed supported columns, 20 angles to be like V, and supply anti-rust galvanized protection wire with a diameter of 0.5 m and carry out the installation accordingly .	ML	75		
	Control room				
17	Supply construction materials (heavy zinc plate and square pipes 8"x4" heavy duty, Cement, concrete, sand, welding rod, and screw) and carry out the installation of the control room accordingly, and Construction of Power control Room 4 m* 3 m *3 m length, width and high respectively.	room	1		
18	hire a winch truck for borehole dismantling and installation, and carry out work at the borehole accordingly, including the installation process of the new submersible pump and other fittings.	truck	1		
19	Supply heavy-duty pipe, Heavy Duty 2 mm x 1 m for borehole protection, and supply construction materials and fix the heavy pipe with concrete accordingly, and carry out the control room platform for the area 3 m width*4 m long*0.05 m thickness	job	1		
20	Provide and installation of Main Gate height 1.80 m*length 3.50 m for water yard. Gate size (1.8m x 3.50m) consists of 2 leafes. Leaf filling is with steel sections 2x4cm vertically and horizontally each 20cm. Gate supports are from steel sections 5x10 cm fixed on plain concrete footing (0.50m x 0.50m x 0.60m) and welded with supported steel section to support the columns. All steel sections must be painted with red-oxide paint and 2 coats of approved oil paint.	Door	1		
Total in Word SDG					

Company/NGO/CBO Name:

Name of Director:

Signature and stamp

Date: